



ActiV Conventional Hi-Output 100dB(A) Wall Sounder (shallow base)

Part No. **BF430C/CC/SR**



Overview

LPCB certified to EN54-3 (Sounders).

Impressive 100dB(A) sound output @ 1m.

31 selectable primary and secondary tone pairs and two volume levels (high and low)

Alarm Current at 30Vdc = 5.5mA.

Alarm Current at 18Vdc = 3.8mA.

IP21C rated.

Manufactured in the UK by C-TEC.

Technical Specifications

| | |
|------------------------------------|---|
| Approvals/certifications | Certified to EN54-3 & 23 by the LPCB. |
| Protocol/compatibility | Compatible with C-TEC's CFP, FP, MFP and EP203 conventional fire alarm panels and virtually all other makes (testing on third-party panels is recommended before use) |
| Application/operation | Designed to be wall mounted. Indoor areas only. |
| VAD category & coverage | N/A |
| Flash rate & colour | N/A |
| Supply/operating voltage | 18 to 30V DC. |
| Nominal SPL (Sound Pressure Level) | 100dB(A). |
| Alarm current | At 30Vdc: 5.5mA; At 18Vdc: 3.8mA. |
| Product dimensions (mm) | 108mm diameter x 99mm deep. |
| IP Rating | IP21C (Type A). |
| Weight | 215g. |
| Operating conditions/temperature | -10°C to +55°C. Max. 95% RH (Non-condensing). |



T 01942 322744 E sales@c-tec.co.uk
F 01942 829867 W www.c-tec.com



C-TEC, Challenge Way, Martland Park, Wigan, WN5 0LD United Kingdom



T 01942 322744 E sales@c-tec.co.uk
F 01942 829867 W www.c-tec.com



C-TEC, Challenge Way, Martland Park, Wigan, WN5 0LD United Kingdom